



GREATER NOIDA INDUSTRIAL DEVELOPMENT AUTHORITY

Plot No.01, Sector Knowledge Park-IV, Greater Noida

Distt.- Gautam Budh Nagar (UP)

Ref.: H.D./2025/ 2007

Date: 26/08/2025

SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by **Senior Manager (Health)** from **Greater Noida Industrial Development Authority, Plot No.-1, Sector Knowledge Park-IV, Greater Noida-201310** PHED inspected the Greater Noida Industrial Development Authority inspected **K.R. Mangalam World School, Plot No. F-2, Pocket P-5, Builders Area, Greater Noida, Distt. G.B. Nagar (U.P.)-201310** on 11.08.2025 certified that the **K.R. Mangalam World School, Plot No. F-2, Pocket P-5, Builders Area, Greater Noida, Distt. G.B. Nagar (U.P.)-201310** maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till for **One Year**.

Signature with Seal: (चेतराम सिंह).....

Name : **Chetram Singh**

Designation : Senior Manager (Health)

Name & Address of the Office / Department :

Greater Noida Industrial Development Authority

Plot No. 1, Sector Knowledge Park IV, Greater Noida

To

The Principal
K.R. Mangalam World School
Plot No. F-2, Pocket P-5,
Builders Area, Greater Noida,
Distt. G.B. Nagar (U.P.)-201310

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



ग्रेटर नौएडा औद्योगिक विकास प्राधिकरण

प्लॉट न०-०१, सैक्टर-के०पी०-४, ग्रेटर नौएडा सिटी, जिला-गौतमबुद्ध नगर (उ०प्र०)।
website: www.greaternoidaauthority.in email id: authority@gnida.in, sm.workcircle.jal@gnida.in


Letter Ref. No.-Jal/2025/720

Date-08/08/2025

SAFE DRINKING WATER CERTIFICATE

It is certified that drinking water as per test report no. W-230625-01(attached) from Office of SHREE RAM TESTING LABORATORIES, Greater Noida in premises was submitted by Principal of K.R. Mangalam World School, Plot No.-F-2, Pocket P-5, Builders Area, Greater Noida found satisfactory. You are requested to ensure to above the condition throughout the norms by the Central/State/UP Govt.

This certificate is valid for one year from date of issue.


Senior Manager (Jal)

To,

The Principal
K.R. Mangalam World School,
Plot No.-F-2, Pocket P-5,
Greater Noida,
G.B. Nagar (U.P.)



Complete Analytical Solution
ISO 14001 : 2015 & ISO 9001 : 2015 Certified

SHREE RAM TESTING LABORATORIES

ISO 14001 : 2015 & ISO 9001 : 2015 Approved Laboratory

Lab: A-2/103, Site-V, UPSIDA Industrial Area, Kasna, Greater Noida-201301

H.O. 223, 2nd Floor, Living Style Mall, Jasola, New Delhi-11002

Mob: 9953984801, 9717160780, 9999024801, E-mail: stl.noida@gmail.com

E-mail: shreeramlab@yohoo.com, info@shreeramlab.com Website: www.shreeramlab.

TEST REPORT

Issued to : M/s K.R. Mangalam World School Plot No. F-2, Pocket P-5, Chi-2, Builder Area, Greater Noida.	Report No.	W-230625-01
	Report date:	27/06/2025
	Sample Received:	23/06/2025
	Analysis date:	23/06/2025 to 27/06/2025
	Sampled By:	customer

Sample Description: R O Water (Drinking water)

Received Sample in Sealed and marked Plastic Bottle

RESULT

Drinking Water-Essential Tests as per IS 10500:2012

S. N.	Parameters (Units)	Test Method	Results	Requirement as per IS: 10500-2012
01.	Odour	IS:3025(P-5) 2018	Unobjectionable	Unobjectionable
02.	Taste	IS:3025(P-8) 1984 (RA- 2017)	Agreeable	Agreeable
03.	Colour (Hazen)	IS:3025(P-4) 2021	<1.0	5 max
04.	Turbidity (NTU)	IS:3025(P-10) 1984 (RA- 2017)	Nil	1 max
05.	pH value (at 25 °C)	IS:3025(P-11) 1983 (RA- 2017)	7.01	6.5 to 8.5
06.	Total Dissolved solids (mg/l)	IS:3025(P-16) 1984 (RA- 2017)	90	500 max
07.	Total Hardness (as CaCO ₃) (mg/l)	IS 3025 P-21:2009 (RA- 2019)	40	200 max
08.	Chloride (as Cl ⁻) (mg/l)	IS:3025(P-32) 1988 (RA- 2019)	4.2	250 max
09.	Iron (as Fe) (mg/l)	IS:3025(P-53) 2003 (RA- 2019)	0.01	0.3 max
10.	Residual Free Chlorine(mg/l)	IS:3025(P-26) 2021	0.012	0.20 max
11.	Fluoride (as F ⁻) (mg/l)	APHA 4500 (D)	0.008	1.0 max
12.	Total Alkalinity (as CaCO ₃), (mg/l)	IS:3025(P-23)- 1986 (RA- 2019)	65	200 max
13.	Magnesium (as Mg), (mg/l)	IS:3025(P-46)- 1994 (RA- 2019)	Nil	30 max
14.	Aluminium (as Al), (mg/l)	IS:3025(P-55)- 2003 (RA- 2019)	Not Detected	0.03 max
15.	Zinc (as Zn), (mg/l)	IS:3025(P-49)- 1994 (RA- 2019)	0.24	5 max
16.	Lead (as Pb), (mg/l)	IS:3025(P-47)- 1994 (RA- 2019)	Not Detected	0.01 max
17.	Mercury (as Hg), (mg/l)	IS:3025(P-48)- 1994 (RA- 2019)	Not Detected	0.001 max
18.	Total Arsenic (as As), (mg/l)	IS:3025(P-37)- 1988 (RA- 2019)	Not Detected	0.01 max
19.	Microbiological Parameters			
I	Coliform (cfu/100ml)	IS 1622:1981 (RA- 2019)	Absent	0 max
II	E. Coli (cfu/100ml)	IS 1622:1981 (RA-2019)	Absent	0 max

Remark: The Tested Parameters meet as per BIS specification.

END OF REPORT

TESTED BY

